



All India Institute of Medical Sciences
Rishikesh

Dated: 27 March, 2019

Corrigendum

In tender document

Tender Enquiry No-22/SE/AC-R/2019-20

As per schedule, Pre- Bid meeting of "Supply, Installation, Testing & Commissioning of 4 Nos Lifts at AIIMS Rishikesh" at AIIMS Rishikesh. was held on 25-03-2019 at 3.00 PM, in the office of Superintending Engineer.

Following modification (deletions/additions/replacements) additions for Tender Enquiry no: - 22/SE/AC-R/2019-20 has been made.

1. Query regarding bid security (EMD) submission as bank guarantee.

Clarification: - Bank guarantee may be submit as bid security (EMD).


2. Query regarding points wise

- a. In technical specifications of lift No.01(freight lift) and lift No.02(for MGPS),S.no.9 Car Group 1C-2BC on tender document page no.29.
- b. In technical specifications of lift no.01(freight lift),S.no.4 Capacity 1600KGS/21PAX on tender document page no.29
- c. In technical specifications of lift no.01(freight lift),S.no.13 Clear cabin internal size 1700 mm(w) on tender document page no.29.
- d. In technical specifications of lift no.01(freight lift),S.no.16 Overhead height 4200 (mm) on tender document page no.29.
- e. In technical specifications of lift no.01 and 02, S.no.23 and lift no.03, S.no.21 Cabin flooring 25 mm recess for Granite on tender document page no.29,30,31 respectively.
- f. In technical specifications of lift no.02(for MGPS),S.no.4 Capacity 825KGS/11PAX on tender document page no.30.
- g. In technical specifications of lift no.02(for MGPS),S.no.13 Clear cabin internal size 1100mm(W)x1750mm(D) on tender document page no.30
- h. In technical specifications of lift no.04(Dumbwaiter),S.no.9 Clear hoist way size per dumbwaiter 1310mm(w)x1180mm(D) on tender document page no.32.

Corrigendum will be part of tender document /Tender inquiry-22/SE/AC-R/2019-20

Clarification

- a. Ignore 1C-2BC and consider selective collective operating method.
- b. Consider capacity 1632KGS/24 PAX.
- c. Consider clear cabin internal size 1800mm(w).
- d. Consider overhead height 4400mm.
- e. Consider aluminum checker plate.
- f. Consider capacity 884KGS/13PAX.
- g. Consider clear cabin internal size 1050mm(w)x2100mm(D).
- h. Consider clear hoist way size per dumbwaiter 1530mm(w)x1260mm(D) after site inspection.



Er.Sulaiman Ahmad

Superintending Engineer

AIIMS Rishikesh